

A minimalist black floor lamp with two vertical cylindrical shades. The lamp has a central black pole and two black cylindrical shades mounted on either side. The shades are oriented vertically, with their open ends facing each other. The lamp is set against a plain, light-colored background. In the bottom left corner, there is a CE mark.

Example: **PONEBB-N-BM-EPF-GX2-HC0510-ZD102102-CN0**

Ground fixing	Shape	Top Set up / Light points	Height	Section	Finish
BM Buried root	EPF Cylindrical	GX2 Max 2 light sources	HC0510 5100 mm	ZD102102 Base 102 - Top 102 mm	CN0 Grey [Neri] Textured
BF Flanged			HC0600 6000 mm	ZD152152 Base 152 - Top 152 mm	
			HC0690 6900 mm		
			HC0780 7800 mm		

Generated code: **PONEBB - N** - - - - -

The product features shown in this datasheet cannot always be freely combined.
To verify the configurations actually available and define the corresponding product code, please use the configurator available on our website.

Nebula | Pole | 2 light sources

MECHANICAL CHARACTERISTICS

Pole in steel UNI EN 10219, hot-dip galvanized according to UNI EN ISO 1461.
CE-certified pole, compliant with standard UNI EN 40-5.

Section	Base/Top 102/102 mm, 152/152 mm
Hatch size	358x78 mm, 558x114 mm
Height under ground	500 mm, 700 mm
Slot height below ground line for cable entry	300x60 mm, 500x95 mm
Weight	50-120.5 kg
Finish	Grey [Neri] Textured

INSTALLATION

Square flange (D) 266 x 266 mm (18 mm thick), for fixing with 4 anchor bolts to a foundation block (anchors and bolts not supplied).

We recommend concealed flange mounting, positioned 100 mm below the finished pavement level.

Square flange (D) 366 x 366 mm (22 mm thick), for fixing with 4 anchor bolts to a foundation block (anchors and bolts not supplied).

We recommend concealed flange mounting, positioned 100 mm below the finished pavement level.

The pole must be embedded 60 cm deep, perfectly plumb, into a concrete foundation block.

The pole must be embedded 80 cm deep, perfectly plumb, into a concrete foundation block.

WARNINGS

Protection of surfaces: please refer to the specification on painting procedures of the materials.